



Existing lighting distribution board to be retained (DB-UG/L). Distribution board to serve lighting installation to ground floor level.

Existing P4 emergency lighting collector box mounted above distribution board to be retained and reused.

| Lighting Legend | |
|-----------------|--|
| Symbol | Description |
| | DEXTRA MODLED OFFICE MODRO L45 C84 |
| | DEXTRA MODLED OFFICE MODRO L45 S C84 (SW DIM) |
| | DEXTRA ARCUS LAY IN ARC L25 1D C84 |
| | DEXTRA ARCUS LAY IN ARC L44 C84 |
| | DEXTRA PROTEC LED PTECD 2000 HF C84 PTEC DWR |
| | P4 FASTEL TriLED, NON-MAINTAINED 3 HOUR EMERGENCY LUMINAIRE |
| | P4 FASTEL QuadLED, NON-MAINTAINED 3 HOUR EMERGENCY LUMINAIRE |
| | P4 FASTEL Beta, WALL MOUNTED 3 HOUR EMERGENCY EXIT SIGN |
| | DEXTRA RUBIX SUSPENDED RBXBD L60 C84 |
| | DEXTRA RUBIX SUSPENDED RBXBD L60 S C84 (SW DIM) |
| | DEXTRA RUBIX SUSPENDED RBXBD L40 C84 |
| | DEXTRA RUBIX SUSPENDED RBXBD L40 S C84 (SW DIM) |
| | EXISTING 600x600mm RECESSED MODULAR LUMINAIRE, AS CONCORD LIGHTING 'OFFICELYTE', 1x55W TC-L (D = DIMMABLE) |
| | EXISTING 600x600mm RECESSED MODULAR LUMINAIRE, AS CONCORD LIGHTING 'OFFICELYTE', 1x80W TC-L (D = DIMMABLE) |
| | SINGLE LIGHT SWITCH (2 = 2-WAY) |
| | INDICATES NO. OF GANGS |
| | RETRACTIVE LIGHT SWITCH (2 = 2-WAY) |
| | PIR DETECTOR (P = PRESENCE, A = ABSENCE) |
| | DENOTES EXISTING EQUIPMENT |
| | DENOTES AREA NOT WITHIN SCOPE OF WORKS |

Revision _____ Date _____ Drn _____ Chk _____
 Client
De Montfort University

Project
John Whitehead Building Refurbishment

Drawing Title
As Fitted Lighting Layout Ground Floor

Suitability Status

Job No. _____ Scale **1:100** Size **@ A1** Rev **AF**

Drawing Number
PO2035/04

MEALEY
 ELECTRICAL CONTRACTORS LIMITED
 Unit 79, Waterside Road,
 Hamilton Industrial Estate, Leicester. LE5 1TL